

YEAR 1986

PCB ANNUAL INVENTORY

TRANSFORMERS

	<u>Quantity</u>	<u>x</u>	<u>PCB's (Kg Each)</u>	<u>=</u>	<u>PCB's (Kg Total)</u>
1. Transformers in Service on 12/31/ <u>86</u>	0		-		0
2. Transformers Removed from Service in <u>1986</u>	0		-		0
3. Transformers in Storage from Previous Year(s) on 1/1/ <u>86</u>	0		-		0
**4. Transformers Transported Off-Site in <u>1986</u>	0		0		0
5. Transformers in Storage on 12/31/ <u>86</u> (2+3-4)	0		-		0
6. Transformers Transported in Previous Years	1		-		0.4
<hr/>					
Total of 1 + 4 + 5 + 6	1				0.4
<hr/>					
*Transformers in Service on 7/2/78	1				0.4

~~*Based on 6/14/84 retest of PCB content on Transformer #25. Retest showed 112 ppm;
previously used PCB content was 99 ppm.~~

**Transformer sold to Electric Equipment Company (Rochester, NY) on 10/29/84 for conversion to non-PCB transformer. Shipped 11/15/84.

PREPARED BY 0002

PAGE 9 OF 10

V.02A.26

MPM0000377

EPA004834